


Towards Standardized Whole Air and Purified Air Gas Production and Characterization for

T2-A15

Theme 2: Accuracy requirements for atmospheric composition measurements across economic sectors, and temporal and spatial scales.

1. Background



The production processes have the advantage of being able to fill large cylinders providing greater amount g gas for the user. The global production rds by blending high purity capacity for both whole air and purified air is limited, noting also that specialty gas producers almost uniq gases rather than by adding components to purified ai

Greenhouse gas standards are used by the atmospheric community for monitoring amount fractions of greenhouse gases (GHGs).

GHG standards are predominantly produced using air matrix that is sourced from:



 Iue(ppm)
 1.8252 CH4
 value(ppm)
 2.1938 CH4

 rent gas
 mass(g)
 u(g)
 Parent gas
 mass(g)
 u(g)

 3205024
 39.3858
 0.0056
 L23205024
 50.8379
 0.005

 4001130
 161.2323
 0.008
 L24001130
 171.6541
 0.008

whole air that has been treated with adsorbents or;

relatively clean, whole air (also referred to as natural air), or;

cryogenically purified of less volatile components (purified air) and compressed.

These processes should leave the major components of air (nitrogen, oxygen and argon) at ambient atmospheric levels so as not to introduce matrix effects that could bias measurements. Potential impacts to the minor component amount fractions are process dependent.

mple of real dilution scheme from pure gases to

٦	CH₄:999999 ppm ↓ +N₂(JFP) CPB-29218	CH₄:999999 ppm ↓ +N₂ (JFI CPB-29219
54	N ₂ :Balance CH ₄ :26329.0 ppm ± 13.2 ppm	N ₂ :Balance CH ₄ :33642.8 ppm ± 11.5 pp
79	↓ +CO ₂ +N ₂ (JFP)	↓ +CO ₂ +N
R.C.	N ₂ :Balance CO ₂ :124099 ppm ± 5 ppm CH ₄ :576.62 ppm ± 0.34 ppm	N ₂ :Balance CO ₂ :117494 ppm ± 5 ppm CH ₄ :673.51 ppm ± 0.32 ppm
55 15	↓ +Ar+N ₂ (JFP) CPB-28223	↓ +Ar+N ₂ CPB-28224
	N ₂ :Balance Ar:100517 ppm ± 6 ppm CO ₂ :4196.9 ppm ± 0.9 ppm CH ₄ :19.502 ppm ± 0.012 ppm	N ₂ :Balance Ar:104084 ppm ± 6 ppm CO ₂ :4226.8 ppm ± 0.8 ppm CH ₄ :24.230 ppm ± 0.013 pp
55 52	↓ +O ₂ +N ₂ (SS) CPB-28035	↓ +O ₂ +N ₂ CPB-28219
55 49	N ₂ :779814 ppm ± 6 ppm (Balance) O ₂ :210538 ppm ± 6 ppm Ar:9259.8 ppm ± 0.7 ppm CO ₂ :386.66 ppm ± 0.09 ppm CH ₄ :1.7973 ppm ± 0.0013 ppm	N ₂ :780898 ppm ± / ppm (Ba O ₂ :209276 ppm ± 7 ppm Ar:9439.9 ppm ± 0.8 ppm CO ₂ :383.39 ppm ± 0.09 ppm CH ₄ :2.1983 ppm ± 0.0013 p

Future activities will focus on working with the atmospheric monitoring community, WMO Central Calibrations Laboratories, National Metrology Institutes, and Specialty Gas Producers in agreeing and publishing acceptable tolerance limits for the composition of air matrix gas, and the performance of measurement methods required to verify this.

Ground-based 🔸 Aircraft 🔺 Ship

Greenhouse Gas Standards

Dr. Edgar Flores, Dr. Bradley Hall, Mrs. Kimberly Harris, Dr. Ray F. Weiss, Dr. Ruth Hill-Pearce, Dr. Robert Wielgosz edgar.flores@bipm.org

2. Requirements for further development

Purified air: potential issues that can be, and on occasion, have been reported are significant deviations in the amount fractions of major components in the air, argon amount fraction for example, and large variations in levels of minor components, such as nitrous oxide, carbon tetrafluoride, sulfur hexafluoride, carbon dioxide and the heavy noble gases. Whole air: it is important that its composition is controlled and can be produced with both major and minor components, including water vapour, within well-defined tolerance limits. - production is predominantly limited to small-scale,

research-oriented facilities

- typically utilizing a breathing-air compressor that is no longer manufactured.

- 1.Work towards increase availability of high quality purified air/whole air matrix gases
- **2. Define acceptable tolerance limits for the composition of these gases**
- 3. Define performance of measurement methods required to verify these limits

4. Recommendations:



Fixed limits for balance gas composition in standards submitted for the comparison. Based upon the possible biases that could be introduced into the spectroscopic comparison methods due to variation in the composition of the air matrix in different standards, participating laboratories were asked to ensure that the composition of Com their air matrix was within these limits.

CCQM-K82 CH₄ comparison

	-	1 - · ·	T.
	150 -	• CCQM-P41 p	oart 1, 2003
	150 -	coordinated by V	/SL
		T M	1 748/
_	100 -		 CCQM-P41 pa
101			2003, coordinated
IOIII IOIIII	50 -		V ~ \
			тТ.
<u>.</u>	-	· · · · · · · · · · · · · · · · · · ·	, , , , , , , , , , , , , , , , , , ,
	0 -		
	-		······································
1	-50 -		<u> </u>
	1.	IMGC CENAM CENAM NOAA NIST KRISS SIRO-AR NMIJ NMI VSL NMIA NMIA	KRISS GUM NIST NMI VSL CEM NMIA NMIA
		NINI N N N N N N N N N N N N N N N N N	NMI G G
	/	Mot	
1		IVIA	t <mark>rix co</mark> m
4			

nponent	Minimum mole	
n Air	permitted w	
	submitted cy	
N ₂	0.7784 mol	
O ₂	0.2077 mol	
Ar	8.8 mmol/	
CO ₂	360 µmol/	

4. Involve standards writing organizations to facilitate uptake by specialty gas industry

This output will provide a significant step forward to the final desired outcome of increased availability, accessibility and affordability of quality assured gas standards for a broad range of GHG measurements.

